

OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES
818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

LIC

WELL PERMIT NUMBER		236658	
DIV. 8	WD 1	DES. BASIN 2	MD

APPLICANT

NICHOLAS L GODDARD
16976 E PROGRESS COUNTY ROAD 5
AURORA, CO 80015-

APPROVED WELL LOCATION
ELBERT COUNTY
NW 1/4 NW 1/4 Section 2
Township 7 S Range 63 W Sixth P.M.

DISTANCES FROM SECTION LINES
214 Ft. from North Section Line
1288 Ft. from West Section Line

UTM COORDINATES
Northing: _____ Easting: _____

PERMIT TO CONSTRUCT A WELL

CONDITIONS OF APPROVAL


- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-90-105.
- 4) Water from this well may be used for domestic purposes inside 3 single family dwelling(s), and the watering of the owner's own large non-commercial domestic animals.
- 5) The maximum pumping rate of this well shall not exceed 15 GPM.
- 6) The annual withdrawal of ground water from this well shall not exceed 3.6 acre-feet.
- 7) The irrigated area shall not exceed 1 acre of lawn and garden.
- 8) Water from this well may be used for the watering of livestock on range and pasture.
- 9) The total depth of the well shall not exceed 775 feet, which corresponds to the base of the Denver aquifer. At a minimum, plain casing shall be installed and grouted through all unconsolidated materials and shall extend a minimum of ten feet into the bedrock formation to prevent production from other zones.
- 10) This well must be constructed within 300 feet of the location specified on this permit.

NOTE: The ability of this well to withdraw its authorized amount of water from this non-renewable aquifer may be less than the 100 years upon which the amount of water in the aquifer is allocated, due to anticipated water level declines.

APPROVED
SMJ



State Engineer



By

Receipt No. 0482505

DATE ISSUED **OCT 01 2001**

EXPIRATION DATE **OCT 01 2003**